# BAPI-Stat 4 Modbus Room Sensor



**Humidity or Combination Temp/Humidity Sensors** 

Rev. 09/14/15

# Features & Options

- Modbus Serial Communications Protocol
- BAPI-Stat 4 Style Enclosure with Optional Large Display
- Robust Tactile Pushbuttons on Display Units
- Setpoint Adjustment on Display Unit with Optional Humidity Measurement, Fan Speed Control and Occupant Override
- Two Year Warranty

The BAPI-Stat 4MB unit features an optional large LCD with all the visual indicators on the display itself. Display units provide local indication of temperature with temperature setpoint adjustment and optional occupant override.

The unit is also available with humidity measurement and fan speed/mode adjustment for applications with fan coils, heat pumps or unit ventilators.



BAPI-Stat 4MB Unit with and without Display, Setpoint and Override

# Specifications

#### Power:

9 to 40 VDC (24 VDC nominal) 24 VAC +20%/-30%.

Note: AC power requires a separate pair of shielded wires.

## **Power Consumption:**

7 mA max DC; .28 VA maximum AC

#### **Sensing Element:**

Thermistor or Semiconductor

#### **Sensor Accuracy:**

Temp: ±0.2°C from 32 to 122°F (0 to 50°C)

%RH: ±2.0%RH (0 to 80%)

Wiring: 2 pair of 14 to 22AWG\*

## Mounting:


Standard 2" by 4" J-box

or drywall mount (screws provided)

### **Environmental Operation Range:**

Temperature: 32 to 122 °F (0 to 50 °C) Humidity: 0 to 95%, non-condensing

Agency: RoHS and CE



# VC350A "EZ" - Voltage Converter

BAPI recommends using DC power on room units for a more stable reading. Our 350mA "EZ" unit is a perfect way to convert 24 VAC to 5, 12, 15 or 24 VDC. The revolutionary "EZ" mounting system allows for snaptrack, DIN rail or surface mounting. See the Accessories section for more info.

\*BAPI recommends that you do not run wiring for the Room Units in the same conduit as line voltage wiring or with wiring used to supply highly inductive loads such as motors, generators and coils. Also, these units are not designed for line voltage applications.



Rev. 09/14/15

Ordering Inf	BAPI-Stat 4MB Room Unit - Temperature and/or Humidity Sensor										
BA/BS4MB	BAP	I-Stat 4	Style En	closure	with Mu	ılti-Mod	e Pushbut	tons			
		olay Mod			Must select one						
		Temper									
		Temper		Displayed	l in °C						
	X		No Display								
		Setpoir	Setpoint Configuration Must select one for display units, not available for non-display units								
		-#	-# SETPOINT DISPLAY OPTIONS								
			Desir	ed Rang	ge_		Designat	<u>or</u>	Desired Range	<b>Designator</b>	
			50 to	90 °F o	r 10 to	32 °C	C D E		65 to 80 °F or 18 to 27	°C <b>F</b>	
			55 to	85 °F o	r 13 to	30 °C	D		70 to 74 °F or 21 to 23		
			60 to	80 °F o	r 15 to	27 °C	E		45 to 96 °F or 7 to 36 °C	C <b>G</b>	
			See App. Notes pg I3 for Additional Setpoint Display Ranges								
			Humidity Measurement Must select one								
					No Humidity Measurement						
			-H2 Humidity Measurement Pushbutton Fan Speed/Mode Options Must select one								
									Must select one		
							d Adjustmo		a diameter control		
									r display units only) r display units only)		
				-F I					select one		
			Override Configuration Must select one  -J Override Enabled (available for display units only)								
						No Ov		a (availai	bic for display drifts offly)		
EXAMPLE						1.10 01					
BA/BS4MB	F	-E	-HN	-FN	-J						
Example Part Number: BA/BS4MBF-E-HN-FN-J											
Your Part Number:											



