Date created, 09/13/2018 - Subject to change. © Belimo Aircontrols (USA), Inc.

P2200S-654,2", Electronic Pressure Independent Valve Stainless Steel Ball and Stem, Female NPT Ends







Technical Data			
Service	chilled or hot water, up to 60% glycol max		
Flow Characteristic	(open loop/steam not allowed)		
	equal percentage or linear		
Valve Size	2 " [50]		
End Fitting	NPT female ends		
Body	forged brass, nickel plated		
Sensor Housing	forged brass, nickel plated		
Ball	stainless steel		
Stem	stainless steel		
Seat	Teflon® PTFE		
Seat O-ring	EPDM		
Characterized Disc	TEFZEL® or stainless steel		
Body Pressure Rating	360 psi		
Media Temperature Range (Water)	14°F to 250°F [-10°C to 120°C]		
Differential Pressure Range	5 to 50 psid, 1 to 50 psid (with flow reduction. See chart.), or 8 to 50 psid (with flow increase. See chart.)		
Close-Off Pressure	200 psi		
Inlet Length to Meet Specified Measurement Accuracy	5X nominal pipe size (NPS)		
Ambient Humidity	<95% RH non-condensing		
Flow Measurement Tolerance	±2%*		
Flow Control Tolerance	±5%		
Flow Measurement Repeatability	±0.5%		
Sensor Technology	ultrasonic with glycol and temperature compensation		
Rangeability	100:1		
Power Supply for the Flow Sensor	sensor is powered by the actuator		
Weight	9.7 lb [4.4 kg]		
GPM	65.4		
Leakage	0%		

^{*}All flow tolerances are at 68°F (20°C) & water.

Application

Water-side control of heating and cooling systems for AHUs and water coils. Equal Percentage/ Linear: heating and cooling applications.

Operation


The Electronic Pressure Independent Control Valve is a two-way valve that maintains constant flow regardless of pressure variations in the system.

Product Features

Provides constant flow regardless of pressure variations in the system. $\label{eq:maximizes} \mbox{ Maximizes chiller P, preventing energizing additional chillers due to low \ T.}$ Simplified valve sizing and selection, no Cv calculations required.

Suitable Actuators


Guitable Hotautore				
	Non-Spring	US only		
P2200S-654	ARB(X)	4349		



Α	В	C	D	E	F
17.04"	11.18"	6.89" [175]	5.59" [142]	1.73	" [44]
[433]	[284]				



P2200S-654,2", Electronic Pressure Independent Valve Stainless Steel Ball and Stem, Female NPT Ends



Α	В	С	D	Е	F
18.23"	11.18"	9.04" [229]	7.79" [198]	1.89	" [48]
[463]	[284]				





Technical Data		
Power Supply	24 VAC, ±20%, 50/60 Hz, 24 VDC, ±10%	
Power Consumption Running	4.5 W	
Transformer Sizing	7 VA (class 2 power source)	
Electrical Connection	3ft [1m], 18 GA plenum cable with 1/2" conduit	
	connector	
Overload Protection	electronic thoughout 0° to 90° rotation	
Operating Range Y	2 to 10 VDC (default) VDC variable	
Input Impedance	100 kΩ (0.1 mA), 500 Ω	
Feedback Output U	default DC 210 V, VDC variable	
Angle of Rotation	90°	
Torque motor	180 in-lbs [20 Nm]	
Direction of Rotation (Motor)	reversible with pc tool	
Position Indication	integrated into handle	
Manual Override	external push button	
Running Time (Motor)	90 sec	
Ambient Humidity	5 to 95% RH non condensing (EN 60730-1)	
Ambient Temperature Range	-22122 °F [-3050 °C]	
Storage Temperature Range	-40176 °F [-4080 °C]	
Housing	IP54, NEMA 2	
Housing Material	UL94-5VA	
Agency Listings†	cULus acc. to UL60730-1A/-2-14, CAN/CSA	
	E60730-1:02, CE acc. to 2004/108/EC and	
	2006/95/EC	
Noise Level (Motor)	max. 45 dB (A)	
Servicing	maintenance free	
Quality Standard	ISO 9001	
Weight	2.6 lb [1.2 kg]	

†Rated Impulse Voltage 800V, Type action 1, Control Pollution Degree 3.







Wiring Diagrams



X INSTALLATION NOTES



Provide overload protection and disconnect as required.



Actuators may be connected in parallel. Power consumption and input impedance must be observed.



Actuators may also be powered by 24 VDC.



Actuators with plenum cable do not have numbers; use color codes instead.



IN4004 or IN4007 diode required



Meets cULus requirements without the need of an electrical ground connection.

WARNING! LIVE ELECTRICAL COMPONENTS!

During installation, testing, servicing and troubleshooting of this product, it may be necessary to work with live electrical components. Have a qualified licensed electrician or other individual who has been properly trained in handling live electrical components perform these tasks. Failure to follow all electrical safety precautions when exposed to live electrical components could result in death or serious injury.

