



### Features

- 15 pipe air sampling
- 0.0003% to 6.10% obscuration/ft (0.001% to 20% obscuration/m)
- 4 Alarms - Alert, Action, Fire 1, Fire 2
- 15 x 164 ft (15 x 50 m) microbore sampling pipe
- Enhanced 0.7 bar rotary vane vacuum pump
- Ethernet TCP/IP
- RS232 and RS485 Modbus
- 5 relay outputs built-in
- Optional relay module and 4 to 20 mA analog output modules
- Area coverage of up to 13,500 ft<sup>2</sup> (1500 m<sup>2</sup>)
- Event Log

### Listings/Approvals

- UL
- ULC
- FM
- VdS
- CE - EMC, LVD and CPD
- EN54-20

Regional approvals listings and regulatory compliance vary between VESDA models.

The VESDA VFT-15 detectors are multi-channel microbore air-sampling systems with an alarm sensitivity range from 0.0003% to 6.10% obscuration/ft (0.001% to 20% obscuration/m). These detectors are classified as Very Early Warning Smoke Detectors and can reliably detect fire at an early stage, and low to high concentrations of smoke. As a multi-channel system, the VFT detector is able to divide a protected space into sampling sectors, enabling the localization of a fire for faster incident response.

The detectors are configurable for a variety of environments, providing ideal fire detection solutions for cabinets, Electronic Data Processing (EDP) rooms, prison cells, historic houses, museums and art galleries.

### How it works

The VFT detector draws a combined air sample from a network of microbore flexible tubing from all sectors in the protected area, then filters and analyzes the sample in a laser detection chamber. When smoke particles are detected and the smoke level reaches a TRACE alarm threshold, the system will sequentially scan the sectors via the rotary valve to identify the sector, or sectors, with the smoke condition. Alarm states (Alert, Action, Fire 1 and Fire 2) are shown on the display and communicated to a host fire alarm control panel.

### Product Features

#### Programming and Configuration

Four independent alarm levels are available for each channel. The smoke thresholds and delays for each of these alarms can be individually programmed per sector. VFT detectors provide a comprehensive display that includes an LED array to show the measured smoke level for the currently selected microbore, and an on-board programmer for local configuration.

RS232, RS485 and TCP/IP communication interfaces are available to connect to Xtralis Configuration and Fire System Management software packages: Xtralis VSC and Xtralis VSM4. RS485 interfaces also allow connections to programming devices and remote displays, and the TCP/IP Ethernet interface can provide access to an email messaging service.


#### Inputs and Outputs

VFT detectors support a number of additional modules. These provide the detector with programmable output relay interfaces and 4 to 20 mA analog outputs. A Remote Display panel can also be connected at a distance of up to 1 km away from the main VFT detector.

## Aspiration and Flow Sensing

The aspirator is a 0.7 bar rotary vane vacuum pump, which provides superior detection times over long pipe lengths and reliable detection in high air flow environments. Airflow in each pipe is monitored by a differential pressure sensor, with airflow faults indicated on the display and to monitoring equipment.

## Dimensions



## Ordering Information

24 VDC, Display/Programmer, TCP/IP, 15 inlets, 0.0003 to 6.1% obs/ft (0.001 to 20% obs/m)	VFT-15-0
4-Channel Relay Module <sup>1</sup>	01-E606-01
8-Channel 4-20 mA Re-Transmission Module <sup>1</sup>	01-E624-01
VFT-15 Remote Display <sup>1</sup>	01-V921-15

**Note:**

1. Please contact your nearest Xtralis office for approvals status.

## Specifications

**Supply Voltage:**  
Nominal 24 VDC

**Supply Current at 24 VDC:**

	Quiescent	Scanning
Power	31.2 W	32.0 W
Current	1.30 A	1.33 A

**Aspirator:**

0.7 bar rotary vane vacuum pump

**Dimensions (WHD):**

19.3 in. x 14.0 in. x 7.9 in.  
(490 mm x 355 mm x 200 mm)

**Operating Conditions: \***

Tested to:

14 to 131 °F (-10 to 55 °C)

Recommended Detector Ambient:

32 to 103 °F (0 to 39 °C)

Sampled Air:

4 to 140 °F (-20 to 60 °C)

Humidity:

10 to 95% RH (non-condensing)

*Please consult your Xtralis office for operation outside these parameters or where sampled air is continually above 0.015% obs/ft (0.05% obs/m) under normal operating conditions.*

**Microbore Size:**

Outer Diameter: 0.24 in. (6 mm)

Inner Diameter: 0.16 in. (4 mm)

**Microbore Length:**

15 x 164 ft (15 x 50m)

Pipe Length: 164 ft (50m)

**Alarm Sensitivity Range:**

0.0003 to 6.10 % obs/ft (0.001 to 20 % obs/m)

**Alarm Settings:**

Alarm levels: Alert, Action, Fire 1 and Fire 2

*Individually programmable for each level*

**IP Rating:**

IP30

**Filtration:**

Field exchangeable dual stage filter

**Flow Monitoring:**

Differential pressure sensor

**Relay Outputs:**

4 alarm relays, 1 fault relay

Rated 2 A @ 30 VDC NO/NC Contacts

**Communication:**

Modbus over RS232, RS485 and TCP/IP

**Event Log:**

Up to 20,000 events stored

\* Product UL listed for use from 0 °C to 38 °C (32 °F to 100 °F)

www.xtralis.com

The Americas +1 781 740 2223 Asia +852 2916 8894 Australia and New Zealand +61 3 9936 7000 Europe, Middle East and Africa +44 1442 242 330

The contents of this document are provided on an "as is" basis. No representation or warranty (either express or implied) is made as to the completeness, accuracy or reliability of the contents of this document. The manufacturer reserves the right to change designs or specifications without obligation and without further notice. Except as otherwise provided, all warranties, express or implied, including without limitation any implied warranties of merchantability and fitness for a particular purpose are expressly excluded.

This document includes registered and unregistered trademarks. All trademarks displayed are the trademarks of their respective owners. Your use of this document does not constitute or create a licence or any other right to use the name and/or trademark and/or label.

This document is subject to copyright owned by Xtralis AG ("Xtralis"). You agree not to copy, communicate to the public, adapt, distribute, transfer, sell, modify or publish any contents of this document without the express prior written consent of Xtralis.

Doc. No. 17510\_08

Part No. 21642