

Restriction Plate Kit for Powerstar Humidity Transmitters and Hygrostats

Product Description

This kit contains the parts needed to install a restriction plate to a Powerstar 186 series room or duct hygrostat or humidity transmitter.

Product Number

180-893

Required Tools

- Flat-blade screwdriver

Expected Installation Time

15 minutes

Installation

1. Remove thermostat or hygrostat from wall.
2. Remove the two screws holding the restriction cover.
3. Remove the old gaskets and restriction plate.
4. Reassemble new kit parts, putting them in the same relative positions as the original parts (see Figure 1). Ensure that the upper restriction gasket connecting the two holes is between the restriction plate and the restriction cover.

NOTE: The restriction hole is closer to the bottom of the unit in vertical models or closer to the left side of the unit in horizontal models.

The installation is now complete.




Figure 1. Restriction Plate Kit Assembly.

Item Number 129-060+2, Rev. BA

Information in this publication is based on current specifications. The company reserves the right to make changes in specifications and models as design improvements are introduced. Product or company names mentioned herein may be the trademarks of their respective owners. © 2013 Siemens Industry, Inc.